



KAGAWARAN NG KATARUNGAN
Department of Justice
 Manila

BIDS AND AWARDS COMMITTEE

Supplemental / Bid Bulletin No. 1
14 June 2023

This Bid Bulletin No. 1 for the Project: “**Supply, Delivery, Configuration, Testing, Commissioning, and Installation of Closed Circuit Television Surveillance System**” is issued to clarify, modify or amend the item/s in the Bidding Documents. Accordingly, this shall form an integral part of the Bidding Documents of the project mentioned.

REFERENCE	CLARIFICATION / AMENDMENT / CHANGE
<p><u>Section VII. Scope of Works and Specifications</u></p> <p>Data Cabinet</p> <p style="text-align: center;">xxx</p> <p>2. 19” standard opening system</p>	<p><u>Section VII. Scope of Works and Specifications</u></p> <p>Data Cabinet</p> <p style="text-align: center;">xxx</p> <p>2 A Intermediate Distribution Frame (IDF) 12U (Depth: between 20 to 24 inches, Width: between 20 to 24 inches, Height: between 21 to 24)</p> <p>B Main Distribution Frame (MDF) 24U (Depth: between 20 to 24 inches, Width: between 20 to 24 inches, Height: between 44 to 48 inches)</p>
<ul style="list-style-type: none"> • Uninterruptible Power Supply (UPS) shall be rack mounted 	
<p><i>Schedule of the Required Site Inspection</i></p> <p>19 to 22 June 2023 (between 9:00 a.m to 12:00 noon)</p> <ul style="list-style-type: none"> • Bidders are advised to coordinate with Mr. Russel Trusmonte, Information and Communications Technology Service, at telephone number 85231581 local 296. • Any bidder who fails to conduct site inspection shall be considered ineligible to participate in the procurement of this project. 	

All terms, conditions, and instructions to bidders specified in the Bidding Documents inconsistent with this Bid Bulletin are hereby superseded and modified accordingly.

For guidance and information of all concerned.



DSP MARGARET V. CASTILLO-PADILLA
Chairperson, Bids and Awards Committee